

**GOVERNMENT OF TELANGANA
FIRE AND EMERGENCY SERVICE**



**STATION FIRE OFFICER
FIRE STATION TURN TABLE LADDER
OFFICE SECUNDERABAD**

To,

**LOTUS NATIONAL SCHOOL,
D.No.3-7-118, Sirmalle Gardens,
Lane beside Bapu Ghat Bridge,
Langar House, Hyderabad.**

Station Fire Officer
Fire Station Langer House,
Hyderabad.

Sub:- FIRE SERVICE DEPARTMENT – Central Region – Hyderabad Division –
Fire Station Langar House – Fire Protection and Control – Inspection of
Above premises against Fire Precautionary and Preventive Measure –
Observance – Regarding.

- Ref:- 1) Annex.XVII of Fire Service Manual Rules.
2) D.O.Lr.No.4646/Genl.B/A1/2002-17, dated: 20-08-2002 of the
Principal Secretary to Government, Home Dept., A.P.Secretariat. Hyd.
3) D.O.Lr.No.856/B2/99, dt: 04-09-2002 of
Director General of Fire Service, A.P.

On inspection of the above mentioned premises on 15-09-2020. It was found that the
Fire Precautionary and Preventive measures have been taken/have not taken as was
mentioned below in the premises.

1. - NIL - Nos. of Soda Acid/Gas pressure water type portable Fire
Extinguishers of 9 Liters capacity each.
2. 6 Nos. of Dry Chemical Powder type portable Fire Extinguishers of
5 KG/10 KG capacity each.
3. - NIL - Nos. of Chemical Foam Type portable Fire Extinguishers of 9
Liters capacity each.
4. 2 Nos. of Carbondioxide Type portable Fire Extinguishers of
2.5/4.5 KG's capacity each.
5. 4 Nos. of Fire Buckets round bottomed each of 9 Liters capacity,
dully filled with clean water/dry sand hanged on a stand at an accessible point in
the premises.
6. Once No. of Standard First-Aid Box with complete accessories.

PRECAUTIONS:

7. Naked Flame should not be used inside the premises.
8. Electrical Wiring should be checked periodically and ensure no loose wiring.
9. General Cleanliness should be observed throughout the premises.

FIRE EQUIPMENT TO BE PROVIDED:

Next Date of Inspection is: 14-09-2021

Yours faithfully,

[Signature] 16/09/2020
**STATION FIRE OFFICER
FIRE STATION TURN TABLE LADDER
SECUNDERABAD**