

5

GREATER WARANGAL MUNICIPAL CORPORATION

From
Sarfraz Ahmad, I.A.S.,
Commissioner,
Greater Warangal Municipal Corporation,
Warangal.

To
The Secretary,
C.B.S.E,
Chennai.

RC. No. HO/DFO/E-3347/GWMC/SCHL/2015 Dt: 23-11-2015

Sub:- Greater Warangal Municipal Corporation - Fire Prevention Wing - Issuance of Fire No Objection Certificate for occupancy to the existing non-MSB of M/s Lotus National School, H.No. 22-7-1/A, Matwada, Warangal -Reg.

- Ref: - 1. Application of the Principal of M/s Lotus National School, H.No. 22-7-1/A, Matwada, Warangal;Dt:20-11-2015.
2. Rc. No. 5041/B2/97, Dt: 12-03-2010 of the Director General, A.P. State Disaster Response and Fire Services, A.P. Hyderabad
3. Inspection report of District Fire Officer, Fire Prevention Wing, GWMC, Warangal, Rc. No.HO/DFO/E-3347/GWMC/SCHL/2015, Dt: 23-11-2015.

With reference 3rd cited, the officers of the Fire Prevention Wing, GWMC have inspected the premises of M/s Lotus National School, H.No. 22-7-1/A, Matwada, Warangal on 23-11-2015.

2. The Management has constructed the Non Multi storied existing School Building with Ground+ First floor with a height of 6.00 mtrs for Educational occupancy (B2) and submitted application for issuance of Fire "No Objection Certificate" for the above existing school building.

3. Particulars of the Building

a) Address of the Building

M/s Lotus National School,
H.No. 22-7-1/A,
Matwada,
Warangal.

b) Total Area of the plot /Ht. of Building :

6655.07 Sq. mtrs / 6.00 mtrs

c) No. of Blocks / Floor :

One Block /Ground+ First Floor

d) Type of occupancy :

Educational Building (B)

e) Floor wise details :

Given Below


Principal

LOTUS NATIONAL SCHOOL
Gouthami Nagar, WARANGAL

(Contd...2nd Page)

Sl. No.	Floor	Area in Sq. mtrs	Occupancy	Occupants Load
1	Ground Floor	623.25	Educational (B)	300
2.	First Floor	623.25	Educational (B)	90
		Total:- 110.96 Sq.mtrs		


4. The Management has provided One stair case with a width of,1.80 mtrs from Ground floor to Terrace floor. The means of escape is satisfactory as per Occupant Load.
5. The following Fire safety measures are provided as per Table 23 of Part - IV of NBC of India 2005. The equipment tested during the inspection and found working satisfactorily.

Sl. No.	Fire Safety Measures	Required	Provided	Deficit
1	Fire Buckets (Sand & Water)	12 Nos	12 Nos	Nil
2	Fire Extinguishers (Water CO2, DCP - 5 kgs and CO2 4.5 Kgs)	6 Nos	6 Nos	Nil

6. In view of the above, Fire No Objection Certificate for Existing School Building from Fire Safety Point of View may be issued subject to the following conditions.

1. The NOC issued is confined to the Fire Safety measures installed in the building and does not confer any Legal right for claiming of Ownership of property or Conversion of land use/ Occupancy or building Regularization. The owner/ Occupier shall comply the Building Rules Govt. Orders as applicable.
2. Excavation plan showing exist routes and recommended action plan be displayed at conspicuous locations and shall be exhibited at all times, all escape / exit routes shall not be locked or encroached.
3. Fresh NOC would be required for any change in occupancy or addition / alterations in the building structure as per NBC and building bye/laws.
4. The Management has to maintain Fire Safety Measures at all times in good working condition as seen during the inspection.
5. Any Loss of life or property due to Non- functioning of Fire Safety Measures and other installations shall be the responsibility of the management/ owner.

(Contd...3rd Page)


Principal
LOTUS NATIONAL SCHOOL
Gouthami Nagar, WARANGAL


6. All the Occupants must know the correct method of operation of the Fire Fighting System installed.
7. Additional / Alteration, if any, in the building may be verified by building authority.
8. The Fire Drills shall be conducted once in every three months for initial two years, thereafter once in every 6 months.
9. This **Fire No Objection Certificate** valid for one year from the date of issue, and it is the responsibility of the builder / occupier to apply for renewal of Fire NOC, one Month before expiry of this Fire NOC.

The Management has remitted Fire precautionary fee through Challan Vide Challan No. 3840, Dt: 20-11-2015 for Rs.12,470/-at SBH, Treasury Branch, Hanamkonda.

Commissioner,
Warangal Municipal Corporation
Warangal.


Copy to:

1. The Principal, M/s Lotus National School, H.No. 22-7-1/A, Matwada, Warangal
2. Regional Fire Officer, Fire Prevention Wing, Greater Warangal Municipal Corporation.


District Fire Officer
Fire Prevention Wing
Municipal Corporation, Warangal

Signature valid

Digitally signed by G. RALA
MURALI MANOHAR REDDY
Date: 2017.11.28 11:58:07 IST
Reason: Approved


Principal
LOTUS NATIONAL SCHOOL
Gouthami Nagar, WARANGAL